



FINANCIAL BIDS

TENDER SCHEDULE OF QUANTITIES FOR AIRCONDITIONING WORKS FOR BANK OF MAHARASHTRA, KARMALA BRANCH, KARMALA

Approved Makes for AC: Toshiba/ Hitachi/ Daikin/LG/Blue star/ Carrier/ Voltas/Mitsubishi
Approved Makes for Stabilizer: V guard or equivalent.

Sr. No	Description	Unit	Quantity	Rate	Amount
A	PART -A - HIGH SIDE WORK				
1	Supplying, erection, testing and commissioning following wall mounted Split/ Roof mounted cassette units of (Toshiba/ Mitsubishi/ Hitachi/ Daikin/LG/Blue star/ Carrier/ Voltas) with cordless remote complete with all necessary fittings duly insulated with 9 mm thick nitrile rubber pipe insulation with (evaporator coil – copper only), fan and fan motor, machine control panel improved Refrigerant Joints, .Air conditioners shall be fitted with hermetically sealed type suction cooled reciprocating or discharge cooled rotary compressor or scroll compressor. Compressor unit operating on R-22/ R-410. All complete as per drawing, approval and instructions of the Employer (Rates to be inclusive of Copper refrigerant pipe with insulation and Drain pipe up to 3 RM. length).				
a	1.0 TR wall mounted split unit (Minimum 5-Star rating inverter type) including all necessary fittings and mountings as specified by the manufacturer.	NO	2		
b	2 TR wall mounted split unit (Minimum 5-Star rating inverter type) including all necessary fittings and mountings as specified by the manufacturer.	NO	4		
	PART A –HIGH SIDE WORK SUB TOTAL AMOUNT				
	SGST @.....				
	CGST @.....				
				Total	

S.No	Description	Unit	Quantity	Rate	Amount
B	PART –B - LOW SIDE WORK				
1	EXTRA REFRIGERANT PIPING				
	Supplying and laying of Extra copper refrigerant piping with nitrile rubber pipe insulation, both of size as specified by the manufacturer suitable for 1.0 TR/2.0 TR Split type AC (From Indoor to outdoor Units) Beyond 3 M.				
a	For 1.0 T Split unit	RM	15		
b	For 2.0 T Split Unit	RM	25		

2	DRAIN PIPING				
	Providing and fixing drain piping up to drain as directed by the engineer in charge with all accessories e.g. elbows, unions, sockets, reducers, reducing tees, nipples etc. Complete job including cutting chiseling in walls, fixing with GI clamps, floor and making good of all chases/cuts etc. and discharging the drain into a floor trap/ gully as per site conditions with insulation, both as specified by the manufacturer. 25 mm dia PVC drain pipe for Split AC	RM	30		
3	AUTOMATIC VOLTAGE CONTROLLER				
	Stabilizer shall be Automatic version with copper coil transformer and the voltage selection range shall be minimum depending on lowest peak recorded average in a month. Precise output voltage range (130V-170V to 240V -270 V). Ensure the rating of Stabilizer shall be in accordance with max rated power of ACs considering instantaneous peak load fluctuation. Providing and fixing Stabilizer with 3-4 step relay and input voltage range of 130-270 V and output to be 230-240 V (Blue bird/ Logic state/ Inline/ V-Gaurd/Equivalent Reputed Make) (copper winding).				
a	5 KVA (For 2.0 TR Split AC)	NO	4		
b	3 KVA (For 1.0 TR Split AC)	NO	2		
4	AIR-CONDITIONERS STAND				
1	MS-STAND -Providing and fixing of lockable caging for outdoor unit grouted on wall or on roof with open able shutter made of 10 X 10 mm MS square bars placed vertically @ 5" c/c welded with 40 X 3 mm MS flat all- round. The frame shall be of angle 35mm*35mm and it shall be fixed to wall or roof with proper MS bracket to tackle the weight of outdoor unit. Item includes all necessary hardware, priming coat, synthetic enamel paint, hanger, clamps other accessories etc. All complete as per approval and instructions of the Bank / Architect. Size shall be adequate for AC outdoor size & sufficient space around the outdoor suitable for servicing purpose for Outdoor unit.	NO	6		
2	Powder coated readymade stands - For 1.0 TR / 2.0 TR Hi Wall split units	NO	6		
5	ELECTRICAL CABLES				
	Suitable IS/BIS standard Cable of 1.1-2.2 KV, Multi strand, FRLS 2- 4 C / 1.5/2.5 -6.0 Sqmm) as per design requirement of Peak load calculation of specific ACs system installed at site with 1"/1/2"/2" PVC conduit pipe between indoor/outdoor unit. Supplying and laying of Extra Electrical interconnecting control cable from indoor to outdoor of size as specified by the manufacturer suitable for 1.0 TR/ 1.5/2.0 TR Split type AC.	RM	45		
6	TIMER				

CONTRACTOR SIGN AND SEAL

	Supplying, installation and commissioning of automatic 24 HRS. Programmable TIMER of required capacity to run A.C. alternately (MDS/ L&T/ Other reputed make).	NO	1		
	PART B –LOW SIDE WORK SUB TOTAL AMOUNT				
	SGST @.....				
	CGST @.....				
	PART B –LOW SIDE WORK TOTAL AMOUNT				
	GRAND TOTAL (PART A + PART B) INCLUDING GST IN FIGURE				
AMOUNT IN WORD-					

NOTES: Note: The rate quoted includes all other taxes, duties, loading, unloading, transportation, other expenses etc. to site only.

All the work of Drain pipe/copper pipe/cable shall be properly supported by clamps from the slab.

Air-conditioning System (Inverter Model/ 5 Star - Wall mounted Split Unit.

Equipment Make –Toshiba/ Hitachi/ Daikin/LG/Blue star/ Carrier/ Voltas/- 5 star split with copper condenser.

DATE-

SIGNATURE AND STAMP OF THE CONTRACTOR

CONTRACTOR SIGN AND SEAL