

**Clarification to Queries - Invitation of Sealed Quotation from eligible bidder for Supply, Delivery, Installation and Maintenance of UPS System & Batteries for branches under Raipur Zone**  
**(Date of Issue: 09.06.2016)**  
**(Clarification: 22.06.2016)**  
**(Last Date of Submission: 24.06.2016)**

S.N.	Query Details	Section No.	Point No.	Description	Bank's Clarification
1	Q1. Kindly Confirm the make of tubular batteries which can be quoted. Can we quote Southern tubular batteries.	Annexure-V	Commercial for 100 AH Tubular Batteries	Batter Type : 12 V 100 AH Exide 6EL Powersafe, Southern Tubular Batteries	Batter Type : 12 V 100 AH Exide 6EL Batteries
2	same as above	Annexure-I,	Specification, Point No. 7	Battery:- Industrial Grade Tubular Batteries (manufacture date should not be more than 3 months from the date of installation) with replacement warranty period of 4 years. For 3KVA - Minimum 12480 VAH for in each UPS with suitable rack For 5KVA - Minimum 24000 VAH for in each UPS with suitable rack Make should be Exide 6EL Tubular / Sothern Tubular	There is no change in specification. Only the battery make should be Exide 6EL Tubular only
3	Q2. Warranty required for tubular batteries is for 03 years or 4 years	Annexure-IV	Commercial for UPS/ Batteries for 5 KVA UPS System	S.N. 2. Battery with 4 Hours Backup with three years warranty	S.N. 2. Battery with minimum 4 Hours Backup with Four years warranty
4	Q2. Warranty required for tubular batteries is for 03 years or 4 years	Annexure-IV	Commercial for UPS/ Batteries for 3 KVA UPS System	S.N. 2. Battery with 4 Hours Backup with three years warranty	S.N. 2. Battery with minimum 4 Hours Backup with Four years warranty

Chief Manager, In Charge  
Raipur Zone