



- NOTE:**
- 1 nos. 6amp. raw power & its switch to be provided above SWC/ Workstations .
  - All AC's stabilizer should be provided within the Electrical panel cabinet.
  - All ac MCB (modular type) to be provided below the AC indoor unit & connection would be from inside, not visible from outside.

LEGEND		S.No	SYMBOL	DESCRIPTION	Nos.			
1		1	BATTEN LIGHT	04	3		6000X600 DOWN LIGHT	12
2		2	DOWN LIGHTER	30	4		LED STRIP LIGHT	10



**BANK OF MAHARASHTRA**  
 Branch of Azra Square,  
 Guar Chowk, Greater Noida

Drawing Title  
**LIGHTING PLAN**

Date  
 03/03/2020

Drawing No.  
 BOM/AD/PV/01

Scale  
 1 : 100

Checked  
 Admitr

**GEOTECH TECHNICAL ASSOCIATES (P) LTD.**  
 G T A  
 ph: 9818938150, 9910297218  
 e-mail: technicalassociates@gmail.com