



बैंक ऑफ महाराष्ट्र
Bank of Maharashtra

भारत सरकार का उद्यम

एक परिवार एक बैंक

CORRIGENDUM - 3

Please refer to RFP 112021-22 published on **27.12.2021** inviting proposal from eligible bidders for **Request for Proposal for CO-HOSTING PRIMARY DATA CENTER & RELOCATING NEAR SITE**. The corrigendum & reply to pre-bid queries are available on Bank's website <https://www.bankofmaharashtra.in> in the Tenders Section.

Deputy General Manager
Information Technology Department



बैंक ऑफ महाराष्ट्र
Bank of Maharashtra
भारत सरकार का उद्यम
एक परिवार एक बैंक

Date: 23.02.2022

CORRIGENDUM - 3

Please refer to RFP 112021-22 published on **27.12.2021** inviting bids for **Request for Proposal for CO-HOSTING PRIMARY DATA CENTER & RELOCATING NEAR SITE.**

Following correction be read in the tender document.

1. Amendment in clauses in RFP. The amendment is enclosed as **Annexure-I.**
2. Change in timelines for Last Date and Time for receipt of tender offers and Date of opening of technical bids enclosed in **Annexure-II.**

Deputy General Manager
Information Technology Department



ANNEXURE-I RFP112021-22 (CORRIGEDUM - 3)

Sr. No.	Page #	Point/ Section	RFP Clause	Clause Revised As
1	14	4.2 Project Scope	The Data Center and Near site should be located in Pune and should be within 25 kms from the each other.	Please read the updated clause as " The Data Center and Near Site should be located in pune within 15 kms from each other. If the bidder has no option for hosting NDR then the bidder can hire services from 3rd party Data Center service provider as per the standards mentioned in the RFP-11202122 and offer it to Bank. The bidder can also offer the NDR in the same campus where DC is Co-hosted but the buildings of hosting DC & NDR should be different and resources should not be shared. The Minimum distance between two buildings should be 500meters.
2	19	5.1.1 General	XIX. The vendor shall provide one-time LAN cabling from the Network rack to the Server Racks as per the network designed finalized with the Bank's network team at no additional cost to the Bank. Vendor to use CAT6A/OM3 cables of any top three OEM. All patch-panels/LIUs will be fully populated with CAT6A/Multimode/Single mode Fibre chords as per requirement/space provisioned to Bank. Vendor to provision passive components on site for immediate replacement/maintenance/connectivity etc.	Please read the updated clause as "The vendor shall provide the one time Cross connect cabling from bidder's tele-communication room to Bank Network/ Server Rack with no additional cost to Bank. Internal LAN cabling between Bank Racks will be done by the Bank.

**Deputy General Manager
Information Technology Department**



Annexure - II

1. Page No. 07: Invitation to the Tender:

Important Information regarding Bid Submission

RFP Term/Clause no. Invitation of the Tender	As per previous Timelines	Revised Timelines
Queries to be mailed by	27.01.2022	Completed
Pre Bid Meeting	04.02.2022 @12:30 PM	Completed
Last Date and Time for receipt of tender offers	28.02.2022 up to 14:00 hrs.	04.03.2022 up to 14:00 hrs.
Date of opening of technical bids	28.02.2022 up to 16:00 hrs.	04.03.2022 up to 16:00 hrs.

Deputy General Manager
Information Technology Department